

## **BANCROFT LEAD WATER TEST RESULTS**

May 24th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
	Building Location													
1	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008243	Utility	Basement	In boiler room spigot	WT-042916-8260- A	< 1	WT-042916-8260- B	< 1				
2	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008244	Cooler	Basement	In lunchroom near entrance	WT-042916-8261- A	< 1	WT-042916-8261- B	< 1				
3	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008245	Kitchen	Basement	In lunchroom kitchen sink	WT-042916-8262- A	< 1	WT-042916-8262- B	< 1				
4	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008246	Kitchen	Basement	In lunchroom kitchen spray nozzle	WT-042916-8263- A	< 1	WT-042916-8263- B	< 1				
5	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008247	Break Room	1	In room 110	WT-042916-8264- A	< 1	WT-042916-8264- B	< 1				
6	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008248	Fountain	1	In room 110	WT-042916-8265- A	< 1	WT-042916-8265- B	< 1				
7	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008249	Cooler	1	In hallway adjacent general office 107	WT-042916-8266- A	< 1	WT-042916-8266- B	< 1				
8	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008250	Health Suite	1	In health suite 103 common sink	WT-042916-8267- A	< 1	WT-042916-8267- B	< 1				
9	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008251	Cooler	1	In health suite 103	WT-042916-8268- A	< 1	WT-042916-8268- B	< 1				
10	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008252	Cooler	2	In hallway adjacent to room 210	WT-042916-8269- A	< 1	WT-042916-8269- B	< 1				
11	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008253	Classroom	1	In classroom 211	WT-042916-8270- A	1.6	WT-042916-8270- B	< 1				
12	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008254	Cooler	2	In hallway adjacent room 213	WT-042916-8271- A	< 1	WT-042916-8271- B	< 1				
13	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008255	Classroom	1	In art room	WT-042916-8272- A	< 1	WT-042916-8272- B	< 1				
14	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008256	Classroom	2	In classroom 313	WT-042916-8273- A	< 1	WT-042916-8273- B	< 1				
15	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008257	Cooler	1	In hallway across from room 314	WT-042916-8274- A	< 1	WT-042916-8274- B	< 1				
16	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008258	Cooler	2	In classroom 313	WT-042916-8275- A	< 1	WT-042916-8275- B	< 1				
17	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008259	Cooler	1	In classroom 314	WT-042916-8276- A	< 1	WT-042916-8276- B	< 1				
18	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008260	Classroom	2	In classroom 314	WT-042916-8277- A	< 1	WT-042916-8277- B	< 1				
19	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008261	Cooler	3	In hallway across classroom 324	WT-042916-8278- A	< 1	WT-042916-8278- B	< 1				
20	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008262	Break Room	3	In teacher's lounge 320	WT-042916-8279- A	< 1	WT-042916-8279- B	< 1				
21	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008263	Cooler	Basement	In hallway across from room 302	WT-042916-8280- A	< 1	WT-042916-8280- B	< 1				
22	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008264	Classroom	Basement	In learning center inner north wall	WT-042916-8281- A	< 1	WT-042916-8281- B	< 1				
23	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008265	Cooler	Basement	In learning center north wall	WT-042916-8282- A	< 1	WT-042916-8282- B	< 1				
24	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008266	Cooler	Basement	In learning center classroom 412B south wall	WT-042916-8283- A	< 1	WT-042916-8283- B	< 1				
25	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008267	Classroom	Basement	In learning center classroom 412B north wall	WT-042916-8284- A	2.1	WT-042916-8284- B	< 1				
26	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008268	Cooler	Basement	In multi-service center (library)	WT-042916-8285- A	< 1	WT-042916-8285- B	< 1				
27	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008269	Cooler	3	In hallway adjacent to in room 221	WT-042916-8286- A	< 1	WT-042916-8286- B	< 1				
28	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008270	Cooler	3	In hallway adjacent classroom 224	WT-042916-8287- A	< 1	WT-042916-8287- B	< 1				
1											Filter will be			
											installed and	l		1
29	BANCROFT ELEMENTARY SCHOOL	5/12/2016	WS- 008271	Classroom	3	In classroom 220	WT-042916-8288- A	< 1	WT-042916-8288- B	21	then retested	l		1
	BANCROFT ELEMENTARY SCHOOL	5/13/2016	WS- 008272	Fountain	Ground Floor	In outside playground inner south wall Low	WT-042916-8289- A	< 1	WT-042916-8289- B	< 1				

## Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.